

ORDERING INFORMATION

MODEL : R7I4DECT-1-YVF4

PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

M-SYSTEM USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)
Ser No.	

Specify the items you want to change.

Default setting will be used if not specified.

■ INPUT RANGE

CHANNEL	SET VALUE	DEFAULT VALUE	Factory Internal check
INPUT 0	<input type="checkbox"/> -10 to +10 V DC <input type="checkbox"/> -5 to +5 V DC <input type="checkbox"/> -1 to +1 V DC <input type="checkbox"/> 0 to 10 V DC <input type="checkbox"/> 0 to 5 V DC <input type="checkbox"/> 1 to 5 V DC <input type="checkbox"/> 0 to 1 V DC <input type="checkbox"/> -0.5 to +0.5 V DC <input type="checkbox"/> CH DISABLE	-10 to +10 V DC	<input type="checkbox"/>
INPUT 1	<input type="checkbox"/> -10 to +10 V DC <input type="checkbox"/> -5 to +5 V DC <input type="checkbox"/> -1 to +1 V DC <input type="checkbox"/> 0 to 10 V DC <input type="checkbox"/> 0 to 5 V DC <input type="checkbox"/> 1 to 5 V DC <input type="checkbox"/> 0 to 1 V DC <input type="checkbox"/> -0.5 to +0.5 V DC <input type="checkbox"/> CH DISABLE	-10 to +10 V DC	<input type="checkbox"/>
INPUT 2	<input type="checkbox"/> -10 to +10 V DC <input type="checkbox"/> -5 to +5 V DC <input type="checkbox"/> -1 to +1 V DC <input type="checkbox"/> 0 to 10 V DC <input type="checkbox"/> 0 to 5 V DC <input type="checkbox"/> 1 to 5 V DC <input type="checkbox"/> 0 to 1 V DC <input type="checkbox"/> -0.5 to +0.5 V DC <input type="checkbox"/> CH DISABLE	-10 to +10 V DC	<input type="checkbox"/>

CHANNEL	SET VALUE	DEFAULT VALUE	Factory Internal check
INPUT 3	<input type="checkbox"/> -10 to +10 V DC <input type="checkbox"/> -5 to +5 V DC <input type="checkbox"/> -1 to +1 V DC <input type="checkbox"/> 0 to 10 V DC <input type="checkbox"/> 0 to 5 V DC <input type="checkbox"/> 1 to 5 V DC <input type="checkbox"/> 0 to 1 V DC <input type="checkbox"/> -0.5 to +0.5 V DC <input type="checkbox"/> CH DISABLE	-10 to +10 V DC	<input type="checkbox"/>

When the CH DISABEL is selected, default value is applied.

■ SCALING

Set zero and full scale to each channel (zero scale to full scale)

CHANNEL	AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
INPUT 0	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>
INPUT 1	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>
INPUT 2	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>
INPUT 3	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>

■ OUTPUT RESET VALUE*1

CHANNEL	AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
INPUT 0	-15.00 to +115.00 (%)	to	-15.00 (%)	<input type="checkbox"/>
INPUT 1	-15.00 to +115.00 (%)	to	-15.00 (%)	<input type="checkbox"/>
INPUT 2	-15.00 to +115.00 (%)	to	-15.00 (%)	<input type="checkbox"/>
INPUT 3	-15.00 to +115.00 (%)	to	-15.00 (%)	<input type="checkbox"/>

*1. When output range is -10 to +10 V DC, approx. -115 V DC at approx. -7.5 to -15% and approx. +11.5 V DC at approx. 107.5 to 115% are outputted respectively.

■ OUTPUT AT COMMUNICATION ERROR

ITEM	AVAILABLE RANGE	DEFAULT VALUE	Factory Internal check
Output at Communication Error	<input type="checkbox"/> Output hold	Output hold	<input type="checkbox"/>
	<input type="checkbox"/> Output clear		